

PRW-9

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123605
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70110

1. OWNER Battle Mt. Truck Stop LLC ADDRESS AT WELL LOCATION 1620 W. Front St.
MAILING ADDRESS P.O. Box 14646 Battle Mt. NV
SPOKANE Valley WA. 99214 Subdivision Name: County: Lander
2. LOCATION NE 1/4 NE 1/4 Sec 18 T 32 N R 45 E Latitude 40.650050 N UTM E NAD 27
PERMIT/WAIVER No. SW Longitude -116.945504 N NAD 83/WGS 84
Parcel No. 02-260-09

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/SILT		0	5	5
SAND		5	10	5
SAND w/ GRAVEL		10	20	10

NAD 27
40.650078
116.944504

RECEIVED
2015 NOV -2 AM 11:22
STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION

Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0	20
Inches		
Inches		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		SCA. 40	0	20

Perforations:

Type of perforation Manufactured
Size of perforation 1.020

From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes No

Neat Cement 0 to 3 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No 4 to 20 Pumped Poured
Type: #3 sand

Bentonite Chips: Yes No 3 to 4 Pumped Poured
Type: 3/8 bent. chips

Date started: 10-14 .20 15
Date completed: 10-14 .20 15

7. Water Level 10 feet below land surface
Static water level:
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gregg Drilling & Testing Inc. Contractor
Address 950 Hawk Rd Martinez, CA 94553 Contractor

Nevada contractor's license number issued by the State Contractor's Board C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2328

Signed [Signature] By driller performing actual drilling on site or contractor
Date 10-19-15