PRW-12

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123608
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70110

1. OWNER Battle Mt. Truck Stop
MAILING ADDRESS P.O. Box 146416
Spokane Valley WA. 99214

ADDRESS AT WELL LOCATION 1460 W. Front St.
Battle Mt. NV.
Subdivision Name: County: Lander

2. LOCATION ~~NE~~ ¼ ~~NE~~ ¼ Sec 18 T 32 N/S R 45 E
PERMIT/WAIVER No. NE
SW Issued by Water Resources
Parcel No. 02-260-09

Latitude 40.649697
Longitude -116.945188
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND/SILT		0	5	5
SAND		5	10	10
SAND W/ GRAVEL		10	20	10

NAD 27
40.649760
116.944268

RECEIVED
OCT 22 2015
DIVISION OF WATER RESOURCES

9. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		SCH. 40	0	20

Perforations:
Type of perforation Manufactured
Size of perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 3 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4 to 20 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 3 to 4 ☐ Pumped ☒ Poured
Type: 3/8 bent. chips

Date started: 10-15 , 20 15
Date completed: 10-15 , 20 15

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gregg Drilling & Testing Inc. (Contractor)
Address 950 Howe Rd Martinez, CA 94553 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 623-0038113
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2328
Signed (By driller performing actual drilling on site or contractor)
Date 10-19-15

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY