

MW-16

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 123610  
Permit No.  
Basin 064

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70110

1. OWNER Battle Mt. Truck Stop LLC  
MAILING ADDRESS P.O. Box 14646  
Spokane Valley WA 99214

ADDRESS AT WELL LOCATION 1600 W. Front St.  
Battle Mt. NV  
Subdivision Name: County: Lander

2. LOCATION NE 1/4 NW 1/4 Sec 18 T 32 N R 45 E  
PERMIT/WAIVER No. M/O-2024  
SW Issued by Water Resources  
Parcel No. 02-260-09

Latitude 40.649492 N UTM E NAD 27  
Longitude -116.945008 N NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/SILT		0	5	5
SAND		5	10	5
SAND w/ GRAVEL		10	20	10

NAD 27  
40.649925  
116.944016

RECEIVED  
21 NOV -2 11 11 22  
STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
20		20	

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 20 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH. 40	0	20

Perforations:  
Type of perforation Manufactured  
Size of perforation 1.020  
From 5 feet to 20 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 3  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No 4 to 30  Pumped  Poured  
Type: #3 sand  
Bentonite Chips:  Yes  No 3 to 4  Pumped  Poured  
Type: 3/8 bent. chips

Date started: 10-12 20 15  
Date completed: 10-12 20 15

7. Water Level  
Static water level: 10 feet below land surface  
Artesian Flow: G.P.M. P.S.I.  
Water Temperature: °F  
Quality:

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Gregg Drilling & Testing Inc Contractor  
Address 950 Howe Rd Martinez CA 94553 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 623-0028113  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2328  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 10-19-15

(Rev. 12-08)

USE ADDITIONAL SHEETS IF NECESSARY