STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123614
Permit No.
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73462
WELL NAME (*If applicable*):

1. OWNER/CLIENT NAME Craig Pickens
MAILING ADDRESS PO Box 1700 Round mt NV 89045 SW

DETAILED ADDRESS AT WELL LOCATION HES 100 PT 35A Smokey Valley NV
Subdivision Name: Round Mt County: NYE

2. PLS LOCATION ~~SE~~ ¼ SW ¼ 26 Sec. 18 N/S 44 E
PERMIT/WAIVER NO. 1005111-04
Issued by Water Resources *Current Parcel No.*

Latitude 38°46.562 UTM E ☐ NAD 27
Longitude 117°00.814 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand Gravel			0	75	
large Gravel		X	75	130	

NAD 27
38.776033
117.013567

RECEIVED 2015 NOV -2 PM 12:20 STATE ENGINEERS OFFICE

Date started: 10-19, 20 15
Date completed: 10-25, 20 15

7. WATER QUALITIES
Static water level: 62 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 48 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
40		8

9. WELL CONSTRUCTION
Depth Drilled: 130 Feet Depth Cased: 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	130 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.7	.188	+18	130

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3 By 3/16
From 115 Feet To 130 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 50			
☒ Neat Cement	0 to 50		☒ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	50 to 130		☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Rosenlund Drilling L.L.C (Contractor)
Address Hc 60 Box 890 Ruby Valley NV 89833 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 0079932
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2465
Signed: [signature] *by driller performing actual drilling on site or contractor*
Date: 10-26-15

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 08-12)
(NSPO Rev 11-12)
(O) 627