STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123628
Permit No. 85433T
Basin No. 189D

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73686
WELL NAME (If applicable): NA

1. OWNER/CLIENT NAME Winecup Gamble Ranch
MAILING ADDRESS P.O. Box 249, Montello, NV 89830

DETAILED ADDRESS AT WELL LOCATION Gamble Road, Montello, NV
Subdivision Name: NA County: Elko

2. PLS LOCATION NE¼ SW ¼ 16 Sec 40 N/S 69 E
PERMIT/WAIVER NO. 85433T (Issued by Water Resources) W690 1 (Current Parcel No.) 010-590-001

Latitude N 41° 20' 53.6" UTM E
Longitude W 114° 10' 13.1" UTM N
☐ NAD 27 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☑ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☐ Air ☑ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
BRN Clay			0	11	11
BLK Clay			11	19	8
BLK sand			19	21	2
Coarse gravel/BLK sand	V	V	21	42	21
BLK clay/gravel			42	60	18
Coarse gravel	V	V	60	87	27
BLK clay			87	90	3
GRY clay/gravel			90	99	9
BLK Clay			99	115	16
RED Clay/rock			115	118	3
RED Clay			118	124	6
Fine gravel/BLK sand		V	124	185	61
Saturated rock			185	200	15
NAD 27					
41.348299					
114.169456					

Date started: 09/26, 20 19
Date completed: 09/29, 20 15

7. WATER QUALITIES
Static water level: 118 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 56 ° Fahrenheit
Water Quality: TDS 160 Ph 7.9

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air lift	30		3

9. WELL CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.3	.188	0	20
6.625	4.95	PVC SDR 17	20	200

PERFORATIONS:
Type of perforation: Factory Saw
Size of perforation: .032
From 120 Feet To 200 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☑ Sanitary Seal	5	to 105		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☑ Concrete Grout	5	to 25	☐ Pumped	☑ Poured
☑ Bentonite Chips	25	to 105	☐ Pumped	☑ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☑ Gravel Pack [> 0.2 in.]	105	to 200	☐ Pumped	☑ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name David Gibson Contractor (Contractor)
Address P.O. Box 203 Lund, NV 89317 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 007788
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2519
Signed: Franton Gibson (By driller performing actual drilling on site or contractor)
Date: 10/08/2015

RECEIVED 2015 OCT 13 PM 12:26 NEVADA DIVISION OF WATER RESOURCES

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12) (O) 627