STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123639
Permit No.
Basin No. 179

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68207
WELL NAME (If applicable):

1. OWNER/CLIENT NAME: Rod Conners
MAILING ADDRESS: P.O. Box 966, McGill, NV 89318

DETAILED ADDRESS AT WELL LOCATION: Kalamazoo Road
Subdivision Name: North Creek
County: White Pine

2. PLS LOCATION: NW ¼ NE SE ¼ SW 20 Sec 19 (N) S 65 E
PERMIT/WAIVER NO. (Issued by Water Resources): 010-710-29 (Current Parcel No.)

Latitude: 114° 41.834' UTM E: ☐ NAD 27
Longitude: 39° 29.890 UTM N: ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top soil			0	4
Sand and clay			4	7
Boulders and gravel		X	7	20
Sand and clay			20	40
Sand and gravel		X	40	55
Clay and small gravel			55	95
Brown clay			95	110
Clay and sand streamers			110	150
Boulders and gravel		X	150	165
Clay and small gravel			165	180
Fractured black volcanic		X	180	195
Black volcanic			195	200

NAD 27
39.498228
114.686385

Date started: 24-Aug, 20 15
Date completed: 28-Aug, 20 15

7. WATER QUALITIES
Static water level: 10 Feet below land surface
Artesian Flow: N/A G.P.M. P.S.I.
Water Temperature: 51 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	88		4

9. CONSTRUCTION
Depth Drilled: 200' Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+18"	20'
6.625	4.95	SDR-17	20'	200'

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	23'	to	100'	☒ Pumped		Poured
☒ Cement Grout	0	to	23'	☐ Pumped	☒	Poured
☐ Concrete Grout		to		☐ Pumped	☐	Poured
☐ Bentonite Chips		to		☐ Pumped	☐	Poured
☒ Gravel Pack [> 0.2 in.]	100'	to	200'	☐ Pumped	☒	Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐	Poured
☐ Other, explain:		to		☐ Pumped	☐	Poured

PERFORATIONS:
Type of perforation: Factory Slot
Size of perforation: 0.032

From	Feet	To	Feet
100	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name (Contractor): Christiansen Drilling Inc
Address (Contractor): 557 Ely Avenue, Ely, NV 89301
Nevada contractor's license number as issued by the State Contractor's Board: #0014790
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1793
Signed: (By driller performing actual drilling on site or contractor)
Date: 9-10-15

RECEIVED 2015 SEP 16 AM 9:14 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.