STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123640
Permit No.
Basin No. 179

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68208
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME: Rod Conner
MAILING ADDRESS: P.O. Box 996
NE McGill, NV 89318

DETAILED ADDRESS AT WELL LOCATION: North Creek
Kalamazoo Road
Subdivision Name: *County:* White Pine

2. PLS LOCATION: ~~NW~~ ¼ SW~~SE~~ ¼ 20 Sec 19 (N)S 65 E
PERMIT/WAIVER NO. 010-710-24
Issued by Water Resources *Current Parcel No.*

Latitude 114° 41.261' UTM E ☐ NAD 27
Longitude 39° 29.953' UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top soil and dirt			0	15
Boulders and gravel		X	15	18
Clay with sand streamers			18	40
Clay with small gravel			40	55
Sand and gravel		X	55	70
Boulders and gravel			70	155
Clay with sand streamers			155	170
Fractured volcanic & clay		X	170	200
Altered volcanic			200	220
Black fractured volcanic		X	220	240

NAD 27
39.499275
114.686835

Date started: 31-Aug, 20 15
Date completed: 5-Sep, 20 15

7. WATER QUALITIES
Static water level: 18 Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: 56° ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	80		

9. CONSTRUCTION
Depth Drilled: 240' Feet Depth Cased: 240' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	20
6.625	4.95	SDR-17	20	240

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement	0 to 100	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	108' to 240'	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory slot
Size of perforation: 0.032

From	Feet	To	Feet
120'		240'	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Christiansen Drilling
Contractor
Address 557 Ely Avenue Ely, NV 89301
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0014790
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1793
Signed: *By driller performing actual drilling on site or contractor*
Date: 9-10-15

RECEIVED 2015 SEP 8 AM 11:1 WATER ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY Pg. 1 of pg.