STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123648
Permit No. 85328E
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72929
WELL NAME *(if applicable)*: MW-6

1. OWNER/CLIENT NAME: Smitten oil and Tire Company
MAILING ADDRESS: PO Box 1235 Fallon,NV,89407

DETAILED ADDRESS AT WELL LOCATION: 1755 West Williams street
Fallon,NV
Subdivision Name: *County:* Churchill

2. PLS LOCATION: SW ¼ SW ¼ 25 Sec 19 N/S 28 E
PERMIT/WAIVER NO.: 85328E *Issued by Water Resources* | 001-251-05 *Current Parcel No.*

Latitude: 39*28'30.51"N UTM E: ☐ NAD 27
Longitude: 118*47'46.84"W UTM N: ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☑ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt+base			0	8"
Silt brown,Moist,Stiff			8"	10
Sand,Dark gray,wet, fine to medium gravel			10	20

NAD 27
39.475224
118.795358

Date started: 9-Sep, 20 15
Date completed: 9-Sep, 20 15

7. WATER QUALITIES
Static water level: 11 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
1.5	0	30 mins

9. CONSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	5.61	0.432	0	20

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☑ Neat Cement	0	to	1	☑ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	1	to	3	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	3	to	20	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..040

From	Feet	To	Feet
5	Feet	20	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP *Contractor*
Address: 4221 West Oquendo Rd, Las Vegas,NV,89118 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0075565
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 25
Signed: *By driller performing actual drilling on site or contractor*
Date: 9/30/2015

RECEIVED 2015 OCT -5 AM 9:06 STATE ENGINEERS OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.