

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 123651  
Permit No. 83224  
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72871  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Perazzo, LLC.  
MAILING ADDRESS 6555 Stillwater Rd  
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 6555 Stillwater Rd  
Fallon, NV 89406  
Subdivision Name: \_\_\_\_\_ County: Churchill

2. PLS LOCATION Sw 1/4 NW 1/4 30 Sec 19 N/S 30 E  
PERMIT/WAIVER NO. 84850/83224 009-101-11  
Issued by Water Resources Current Parcel No.

Latitude 39.48435 UTM E  NAD 27  
Longitude -118.66695 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	3
Sand			3	24
Brown Clay			24	40
Green Clay			40	51
Gray Clay			51	53
Brown Clay			53	61
Black Sand			61	63
Black Sand			63	65
Gray Sand			65	90
Gray/Brown Sand			90	97
Brown Clay			97	112
Green Clay			112	119
Black Sand			119	120
Black Clay			120	122
Fine Black Sand			122	138
Black Clay/Sand			138	175
Green Sand			175	181
Green Clay			181	185
Green Sand			185	215
Gray Sand			215	227
Clay			227	233
Green Sand			233	239
Green Clay			239	240
Green Gravel		X	240	250

9. INSTRUCTION  
Depth Drilled: 250 Feet Depth Cased: 250 Feet

HOLE DIAMETER (BIT SIZE)			
	From	To	
	<u>14</u> Inches	<u>0</u> Feet	<u>250</u> Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>16.96</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>8</u>	<u>6.69</u>	<u>.411</u>	<u>20</u>	<u>250</u>

ANNULAR MATERIALS  
Sanitary Seal  Yes  No

<input checked="" type="checkbox"/> Neat Cement <u>5</u> to <u>105</u>	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Bentonite Chips _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Gravel Pack [ > 0.2 in. ] <u>105</u> to <u>250</u>	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Sand Pack [ < 0.2 in. ] _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Other, explain: _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

Date started: 18-Sep 20 15  
Date completed: 19-Sep 20 15

PERFORATIONS:  
Type of perforation: Saw Cut  
Size of perforation: 1/8  
From 247 Feet To 250 Feet  
From NAD 27 Feet To \_\_\_\_\_ Feet  
From 39.484431 Feet To \_\_\_\_\_ Feet  
From 118.665969 Feet To \_\_\_\_\_ Feet

7. WATER QUALITIES  
Static water level: 26 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Parsons Drilling, Inc.  
Address P.O. Box 1265 Fallon, NV 89406  
Nevada contractor's license number as issued by the State Contractor's Board: 29064  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2509  
Signed: [Signature]  
Date: 9/30/2015

8. WELL TEST DATA

Test Method:	<input type="checkbox"/> Bailor	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.		Draw Down (Feet Below Static)	Recorded Time (Hours)