STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123709
Permit No.
Basin 087

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73055

1. OWNER Lee Saloutos
MAILING ADDRESS 325 Chariman Rd
Richmond VA 23226

ADDRESS AT WELL LOCATION 123 Anitra
Reno, NV 89511
Subdivision Name: County: Washoe

2. LOCATION NE ¼SW ¼ Sec 2 T 18 N/ R 19 E
PERMIT/WAIVER NO. DOM-15-23 (Issued by Water Resources) 041-290-23 (Parcel. No.)

Latitude 39.451412 UTM E ☐ NAD 27
Longitude -119.821407 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay & Some Cobbles		0	130	130
Orange Clay & Some Cobbles		130	150	20
Brown Clay & Some Cobbles		150	190	40
Grey Clay		190	193	3
Brown Clay	X	193	215	22
Grey Clay		215	220	5
Grey Broken Rock	X	220	240	20

NAD 27
39.451501
119.820383

Date started: 7-31, 20 15
Date completed: 8-3, 20 15

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 SS	12.92	.188	+2	240

Perforations:
Type of perforation Factory
Size of perforation SS Louvered Screen .080 Slot
From 240 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 105 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 105 to ~~335~~ 240 ☐ Pumped ☒ Poured
Type: #6 Gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 142 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: 58 °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	20-30		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed
By driller performing actual drilling on site or contractor
Date 8-10-15

RECEIVED 2015 SEP 30 AM 9:5 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Replacing well log 51906