

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 123793  
 Permit No. \_\_\_\_\_  
 Basin 071

**PRINT OR TYPE ONLY**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74198

1. OWNER **Dennis & Mary Libro**  
 MAILING ADDRESS 7485 Allen Road  
 ADDRESS AT WELL LOCATION **7485 Allen Road**  
**Winnemucca, NV 89445**  
 Subdivision Name: \_\_\_\_\_ County: **Humboldt**

2. LOCATION **SW 1/4 NE 1/4 Sec 13 T35N R37E**  
 PERMIT/WAIVER NO. N/A **3537-13-252-005**  
*Issued by Water Resources* Parcel No. \_\_\_\_\_  
 Latitude **40.90891** UTM E \_\_\_\_\_  NAD 27  
 Longitude **117.76544** N \_\_\_\_\_  NAD 83/WGS 84

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	7	7
Gravel & Cobles		7	30	23
Boulders		30	40	10
Cobles & Gravel		40	80	40
Clay		80	85	5
Gravel & Cobles	X	85	140	55
Clay		140	145	5
Cobles & Gravel	X	145	165	20
Boulders		165	170	5
Cobles & Gravel	X	170	200	30
Boulders		200	205	5
Gravel & Cobles	X	205	260	55

*NAD 27  
 40.909006  
 117.764477*

9. WELL CONSTRUCTION  
 Depth Drilled **260** Feet Depth Cased **260** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **11** Inches To **0** Feet **260** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>10</b>	<b>.188</b>	<b>+18"</b>	<b>260</b>

Perforations:  
 Type of perforation **Factory Cut**  
 Size of perforation **3/32X3**  
 From **220** feet to **260** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement **5** to **55**  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No **55** to **260**  Pumped  Poured  
 Type: \_\_\_\_\_

Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **October 13, 2015**  
 Date completed: **October 15, 2015**

7. Water Level  
 Static water level: **127** feet below land surface  
 Artesian Flow: N/A G.P.M. N/A P.S.I.  
 Water Temperature: **62** °F  
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	□ Bailer	□ Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<b>40-50</b>			<b>4</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)  
 Address **10760 S. Grass Valley Road** (CONTRACTOR)  
**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **021467**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: **2083**

Signed *Fred Anderson*  
 By driller performing actual drilling on site or contractor  
 Date **November 13, 2015**

*Replacing unknown well log*

RECEIVED  
 NOV 18 AM 11:09  
 STATE ENGINEER OF NEVADA