STATE ENGINEER'S OFFICE
ELKO OFFICE

RECEIVED
NOV 04 2015

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123795
Permit No.
Basin No. 054

NOTICE OF INTENT NO. 73276
WELL NAME (*If applicable*):

1. OWNER/CLIENT NAME John Nabong
MAILING ADDRESS

DETAILED ADDRESS AT WELL LOCATION 250 N. 11st. Cresent Valley NV
Subdivision Name: CVR #4 *County:* Eureka

2. PLS LOCATION NW ¼ NW ¼ 21 Sec 30 N/S 48 E
PERMIT/WAIVER NO. ~~003-09-04~~
Issued by Water Resources *Current Parcel No.* → 003-094-04

Latitude 40 27.721 UTM E ☐ NAD 27
Longitude 116 33.934 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☐ Air ☑ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	2
Sand/Gravel w/Clay Seams			2	60
Hard Brow Clay			60	68
Volcanic Ash			68	105
Medium Gravel some sand			105	150

NAD 27
40.462101
116.564648

Date started: 3-Oct , 20 15
Date completed: 8-Oct , 20 2015

7. WATER QUALITIES
Static water level: 58 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Drew Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	35	104	4

9. CONSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		SDR17	150	30
6/58	12	.188	30	+1.5

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☑ Neat Cement	28	to 4	☐ Pumped	☑ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☑ Bentonite Chips	55	to 28	☐ Pumped	☑ Poured
☑ Gravel Pack [> 0.2 in.]	150	to 55	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Manufactured
Size of perforation: 0.32

From 150	Feet	To 130	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Reese Johnson
Contractor
Address 197 Western Hills #7 Spring Creek NV. 89815
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 073995
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2421
Signed:
By driller performing actual drilling on site or contractor
Date: 10/15/2015

RECEIVED
NOV 18 2015
STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.