Log No. 123811

Basin 110C

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74381
WELL NAME (if applicable): IW-17

1. OWNER/CLIENT NAME Hydro Geologic
MAILING ADDRESS 14142 Denver W Pkwy
Lakewood CO 80401

DETAILED ADDRESS AT WELL LOCATION Grant Ave and 3rd Ave North (Central Magazine Hawthorne AAD
Subdivision Name: County: Mineral

2. PLS LOCATION ¼ SW ¼ SE Sec 12 N/S 30 E
PERMIT/WAIVER NO. M0-2019 (Issued by Water Resources) T8N (Current Parcel No.)

Latitude 362081.063227 UTM E ☐ NAD 27
Longitude 4269680.960783 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☒ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Blind drill RVC			0	115
Silty Sand			115	119
Clayey Silt w/ Sand			119	120
Sandy Clay			120	123
Sand			123	125
Sandy Clay			125	128
Sand			128	130
Clay			130	133
Clay w/ Sand			133	135
Sandy Clay			135	144
Clayey Sand			144	145
Clay w/ Sand			145	150
NAD 27				
38.564953				
118.582088				

Date started: 10-8, 20 15
Date completed: 10-8, 20 15

9. CONSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 126 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch 40	Sch 40	0	126

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 121	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	121	to 124	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	124	to 150	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: .020
From 126 Feet To 146 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Major Drilling America Inc (Contractor)
Address 2200 S 4000 W Salt Lake City UT 84120 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0062830
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1988
Signed: [signature] By driller performing actual drilling on site or contractor
Date: 10/25/15

RECEIVED
OCT 12 PM 2:13
ENGINEERS OFF

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1