Corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123910
Permit No.
Basin No. 061

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73718
WELL NAME (if applicable): MW-1

1. OWNER/CLIENT NAME Barrick Goldstrike mines Inc.
MAILING ADDRESS PO Box 29 Elko NV. 89803

DETAILED ADDRESS AT WELL LOCATION Arturo
Subdivision Name: County: Eureka

2. PLS LOCATION NE ¼ NW ¼ 34 Sec 37N N/S 49 E
PERMIT/WAIVER NO. MO-2034 (Issued by Water Resources) Current Parcel No.

Latitude UTM E 548138.2286 ■ NAD 27
Longitude UTM N 4543846.489 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ■ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ■ RVC
■ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Aluvium			0	102

NAD 27
41.046333
116.427233

Date started: 11-24, 20 15
Date completed: 11-24, 20 15

9. CONSTRUCTION
Depth Drilled: 102 Feet Depth Cased: 102 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	20	Feet
8 1/2	Inches	20	Feet	102	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2		Sec. 80	+1 1/2	102

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

■ Neat Cement	0	to 20	☐ Pumped	■ Poured
■ Cement Grout	0	to 18'	☐ Pumped	■ Poured
■ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips	18	to 20	☐ Pumped	■ Poured
☐ Gravel Pack [> 0.2 in.]		to	■ Pumped	☐ Poured
■ Sand Pack [< 0.2 in.]	20	to 102	■ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Machine
Size of perforation: .020

From 22	Feet	To 102	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: 0 dry hole Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	Dry hole	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear Company (Contractor)
Address PO Box 2748 Elko, NV. 89803 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1395

Signed: (By driller performing actual drilling on site or contractor)
Date:

RECEIVED DEC 11 2015 10:16 AM ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1