

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 123916  
 Permit No. 31011  
 Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71287

1. OWNER **Gar & Filis Takus**  
 MAILING ADDRESS **PO Box 191WInnemucca, NV 89445**

ADDRESS AT WELL LOCATION **Paradise Valley**  
 Subdivision Name: \_\_\_\_\_ County: **Humboldt**

2. LOCATION **NW1/4NW1/4 Sec12T39N/ R38E**  
 PERMIT/WAIVER NO. **31011** Parcel No. **N/A**  
*Issued by Water Resources*

Latitude **41.16'37.7"** UTM E  NAD 27  
 Longitude **117.39'12.3"** N  NAD 83/WGS 84

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Clay		0	40	40
Clay/streamers/sandstone		40	75	35
Course Sand		75	90	15
Clay		90	92	2
Course Sand	X	92	140	48
Sandstone		140	150	10
Clay		150	152	2
Course Sand	X	152	225	73
Clay streamers/Sand	X	225	260	35
Sandstone	X	260	265	5
Clay		265	270	5
Sandstone		270	285	15
Clay		285	290	5
Fine Gravel & Sand	X	290	320	30
Course sand/clay streamer	X	320	340	20
Clay		340	350	10
Sandstone/clay streamer		350	370	20
Clay		370	400	30

9. WELL CONSTRUCTION  
 Depth Drilled **400** Feet Depth Cased **400** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 30 Inches \_\_\_\_\_ 0 Feet \_\_\_\_\_ 50 Feet  
 25 Inches \_\_\_\_\_ 50 Feet \_\_\_\_\_ 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	.102	3/8	+18"	50
16	42	5/16	+18"	400

Perforations:  
 Type of perforation **Factory Cut**  
 Size of perforation **1/4" x 3"**  
 From \_\_\_\_\_ 400 feet to \_\_\_\_\_ 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout **0** to **50**  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No **50** to **400**  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **Sept 1, 20 15**  
 Date completed: **Sept 15, 20 15**

7. Water Level  
 Static water level: **67** feet below land surface  
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.  
 Water Temperature: **60** °F  
 Quality: **Good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)  
 Address **10760 S. Grass Valley Road** (CONTRACTOR)  
**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **021467**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**  
 Signed *Chris [Signature]* **11-30-15**

8. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Draw Down (Feet Below Static)		Time (Hours)
	<b>2000</b>		<b>12</b>

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com

*Replacing well log 20513*

RECEIVED  
 25 DEC - 2 AM 10:14  
 ENGINEERS