STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123924
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73125-36
WELL NAME (*If applicable*):

1. OWNER/CLIENT NAME EVAN WRIGHT
MAILING ADDRESS GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION CALLE DE SOL NO ADDRESS
GARDNERVILLE, NV 89410
Subdivision Name: *County:* Douglas

2. PLS LOCATION SE ¼ NE SE ¼ 31 Sec 13 N/S 21 E
PERMIT/WAIVER NO. 1321-31-002-004
Issued by Water Resources *Current Parcel No.*

Latitude 38.943511*N UTM E ☐ NAD 27
Longitude 119.661986*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
SMALL CLAY STRATAS				
SMALL GRAVELS			3	85
BROWN CLAY			85	135
DG SANDS AND CLAY			135	210
BROWN GUMMY CLAY			210	245
OBSIDIAN GRAVELS		XXX	245	300
NAD 27				
38.943602				
119.660980				

Date started: 12-Oct , 20 15
Date completed: 14-Oct , 20 15

9. CONSTRUCTION
Depth Drilled: 300' Feet Depth Cased: 300' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	300
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 100	☐ Pumped	☐ X Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to 300	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: .032 X 3

From	Feet	To	Feet
260	Feet	300	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 95 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 46° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30+	65	3 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed
By driller performing actual drilling or his or contractor
Date: 10/18/2015

RECEIVED 2015 OCT 28 AM 10:08 DIVISION OF WATER RESOURCES ENGINEERS OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.