WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123942
Permit No. 17785
Basin 030A

NOTICE OF INTENT NO. 71346

1. OWNER Brian Rookstool
MAILING ADDRESS 121 Kings River Road
Orovada NV 89425

ADDRESS AT WELL LOCATION 36860 Kings River Road
41.742823 North
Longitude 118.225595 NAD 83

2. LOCATION NW ¼ NW ¼ Sec. 36 T. 45 N/S R. 33 E. Humboldt County
PERMIT NO. 17785 Issued by Water Resources
~~02-251-15~~ Parcel No.
P15-07 Aug 31 2015 under permit #17785
4533-36-200-001 ~~Subdivision Name~~

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5'
Sand & Clay		5	150	145'
Gravel		150	190	40'
Sand & Clay		190	447	257'
Clay		447	450	3'

NAD 27
41.742925
118.224606

Date started 2/18/2015, 19—
Date completed 4/10/2015, 19—

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	0	

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24" Inches	0 Feet	155 Feet
19" Inches	155 Feet	448.5 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18"	60 ~~lbs~~	.312	0	448.5

Perforations:
Type perforation Virtical
Size perforation .118 x 4"
From 90' feet to 447' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 51' feet to 450' feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow -0- G.P.M. -0- P.S.I.
Water temperature 55 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jerry Mortic Contractor
Address PO Box 3791 Contractor
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board -0-
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 930
Signed [signature]
By driller performing actual drilling on site or contractor
Date 9-10-15

RECEIVED 2015 OCT 13 AM 10:37 STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

Replacing WELL log 4847