STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123959
Permit No. 79783
Basin 230

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35765

1. OWNER Amargosa Valley Solar I LLC
MAILING ADDRESS 1625 Shattuck Ave 270 Berkeley, Cal. 94709
ADDRESS AT WELL LOCATION 300 N. Casada Way Amargosa, Nv.
Subdivision Name: County: Nye.

2. LOCATION NE¼ NE ¼ Sec 23 T 16 N OR 48 E
PERMIT/WAIVER No. 79783 (Issued by Water Resources) 019 691 02 (Parcel No.)
Latitude 36° 33 258 N Longitude 116° 31. 511 W
UTM E N
☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE INDUSTRIAL - DSS
☐ Domestic ☑ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand, clay		0	15	15
silt, sand		15	120	105
clay		120	135	15
silt, sand	x	135	250	115
sandy clay		250	300	50
silt, sand	x	300	410	110
clay		410	460	50
silt, sand	x	460	490	30
clay		490	520	30
sand	x	520	560	40
clay		560	600	40

NR/DWR/SNR RECEIVED SEP 08 2015

Date started: Mar 25, 20 12
Date completed: May 5, 20 12

7. Water Level
Static water level: 131.8 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	700		12 hours
Test pump	2500	135'	60 hours

9. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
25 Inches		0 Feet	600 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.3	.375	+2	600

Perforations:
Type of perforation Factory milled
Size of perforation 3/16 x 2½
From 200 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☑ Concrete Grout 0 to 52 ☐ Pumped ☑ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☑ Yes ☐ No 52 to 600 ☐ Pumped ☑ Poured
Type:
Bentonite Chips: ☐ Yes ☑ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Webber Drilling (Contractor)
Address PO Box 40 Overton Nv. 89040 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone (By driller performing actual drilling on-site or contractor)
Date 9-7-15

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

36.5543752
-116.5242884
NAD 27

(O) 627