WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123962
Permit No.
Basin

NOTICE OF INTENT NO. 33142

1. OWNER Dawn and Orland Dona
MAILING ADDRESS 1411 Marion Miller
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3480 S. Sopio Ave. 36D 10'6.58"N 116D 2'8.86"W

2. LOCATION S/E 1/4 N/E 1/4 Sec. 32 T 20S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources | 40-581-10 Parcel No. | Calvada Unit 5 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown clay | | 0 | 22 | 22 |
| See next line | x | 22 | 85 | 63 |
| brown clay with caleche strings | | | | |
| brown caleche | x | 85 | 185 | 100 |
| brown clay | x | 185 | 200 | 15 |

DCNR/DWR/SNBO RECEIVED NOV 12 2015

DCNR/DWR/SNBO RECEIVED NOV 12 2015

Date started 11/5/1915 2015 DSB, 19__
Date completed 11/5/1915, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 11 | Inches | 0 Feet | 200 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.7 | .280 | 0 | 200 |
| | | | | |

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed By driller performing actual drilling on-site or contractor
Date 11.6.15

RECEIVED 2015 NOV -9 PM 2:9 STATE ENGINEER'S OFFICE

36.1685324
-116.0349334

NAD 27