WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123963
Permit No.
Basin 162

NOTICE OF INTENT NO. 33140

1. OWNER Doug Olson
MAILING ADDRESS 6091 S. VickiAnn
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
6091 S. VickiAnn 36D7.50.2"N 115D58'28.44"W

2. LOCATION N/W 1/4 N/W 1/4 Sec. 13 T 21S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources | 44-581-09 Parcel No. | Conestoga County Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	10	10
See next line		10	23	13
brown loam with caleche strings				
brown clay	x	23	128	105
brown caleche	x	128	142	14
See next line	x	142	188	46
grey clay with caleche strings				
brown caleche	x	188	200	12

DCNR/DWR/SNBO
RECEIVED
NOV 12 2015

Date started 11/1/1915 2015, 19__
Date completed 11/1/1915 2015, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 11/6/15

RECEIVED
2015 NOV -9 PM 2:18
STATE ENGINEER'S OFFICE

36.1306499
-115.9737081
NAD 27