

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 123965
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33141

1. OWNER **Steven Settlemeyer** ADDRESS AT WELL LOCATION
 MAILING ADDRESS **3006 LaMesa Drive** **3451 E. Tillman 36D4°34.23"N 115D 56'55.49"W**
Henderson, NV 89014

2. LOCATION **S/E** 1/4 **S/W** 1/4 Sec. **31** T **21S** N/S R **54E** E **Nye** County
 PERMIT NO. **45-441-13** **Cal-Vista** Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty loam		0	12	12
loam		12	19	7
brown caleche		19	23	4
See next line		23	42	19
brown loam with caleche strings				
brown loam		42	83	41
See next line	x	83	172	89
brown loam with caleche strings				
gravel	x	172	250	78

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	250

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**
 From 200 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 10/31/1915 2015, 19
 Date completed 11/1/1915, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **5801 S. Homestead** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2096**
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 11.6.15

36.0762103
 -115.9478931
 MAD
 27

RECEIVED
 2015 NOV -9 PM 2:16
 STATE ENGINEERS
 RECEIVED