STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123970
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37320

1. OWNER MICHAEL UTLEY
MAILING ADDRESS 3660 S TOURNAMENT
PAHRUMP NV 89048-5772

ADDRESS AT WELL LOCATION 3660 S TOURNAMENT
PAHRUMP
Subdivision Name: U4 A CALVADA VLY County: NYE

2. LOCATION NW ¼ SW ¼ Sec 34 T 20S N/S R 53 E
PERMIT/WAIVER No. 40-681-11
Issued by Water Resources Parcel No.

Latitude N36°09'57.8"" Longitude W116°00'43.8"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING		0	140	-140
CLAY		140	185	-45
CALICHIE	WB	185	200	-15
CLAY & CALICHIE	WB	200	260	-60

Original well log # 51747

Date started: 14-Oct , 20 15
Date completed: 14-Oct , 20 15

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	140	Feet
7-7/8	Inches	140	Feet	260	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.794	.032	6	200
4.5	2.794	.032	200	260

Perforations:
Type of perforation SLOT
Size of perforation .032
From 200 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 260 to 6 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 82 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2513
Signed
By driller performing actual drilling on site or contractor
Date 10/15/2015

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

CONTRACTORS BOARD
OCT 23 2015

36.1660938 NAD
-116.0113079 27