

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123974
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37832
WELL NAME (if applicable): MW-9

1. OWNER/CLIENT NAME MB REO-NV-Industrial
MAILING ADDRESS 515 S. Flower St. 44th fl.
Los Angeles, CA 90071

DETAILED ADDRESS AT WELL LOCATION 3463 Procyon St.
Las Vegas, NV
Subdivision Name: _____ County: Clark
Latitude 36°07'37.54"N UTM E NAD 27
Longitude 115°11'17.47"W UTM N NAD 83/WGS 84

2. PLS LOCATION NW 1/4 NW 1/4 17 Sec 21 N/S 61 E
PERMIT/WAIVER NO. MO-3106 162-17-101-018
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Corn / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
<u>Silly Clay, stiff</u>			<u>1.5</u>	<u>6</u>
<u>Silly Sand, fine</u>				
<u>Back at 6</u>			<u>6</u>	<u>9</u>
<u>Cemented Sand / Gravel</u>			<u>9</u>	<u>11</u>
<u>Silly Clay, partly</u>				
<u>Cemented moist</u>			<u>11</u>	<u>13</u>
<u>Sandy gravel, moist-</u>				
<u>Wet Very dense</u>			<u>13</u>	<u>24</u>
<u>Clayey gravel, coarse</u>				
<u>wet, very dense</u>			<u>24</u>	<u>27</u>

9. INSTRUCTION

Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)				
	From	To		
<u>8.25</u>	<u>0</u>	<u>25</u>	Feet	Feet
			Inches	Feet
			Inches	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>0</u>	<u>25</u>

ANNULAR MATERIALS

Sanitary Seal Yes No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	<u>0</u> to <u>11</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input checked="" type="checkbox"/> Bentonite Chips	<u>11</u> to <u>13</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Gravel Pack [> 0.2 in.]	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Sand Pack [< 0.2 in.]	<u>13</u> to <u>25</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Other, explain:	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

25-27 Sand

PERFORATIONS:

Type of perforation: Factory

Size of perforation: .020

From <u>15</u>	Feet	To <u>25</u>	Feet
From _____	Feet	To _____	Feet
From _____	Feet	To _____	Feet
From _____	Feet	To _____	Feet

Date started: 10-15 20 15
Date completed: 10-16 20 15

7. WATER QUALITIES
Static water level: 13.8 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 4221 W. Oquendo Rd. Las Vegas, NV 89118 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526
Signed: [Signature]
Date: 10/28/2015

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

36.1271237
-115.1873527
NAD
27