

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 123975  
Permit No. \_\_\_\_\_  
Basin No. \_\_\_\_\_

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37832  
WELL NAME (if applicable): MW-8

1. OWNER/CLIENT NAME MB REO-NV-Industrial  
MAILING ADDRESS 515 S. Flower St. 44th fl.  
Los Angeles, CA 90071

DETAILED ADDRESS AT WELL LOCATION 3463 Procyon St.  
Las Vegas, NV

2. PLS LOCATION NW 1/4 NW 1/4 17 Sec 21 N/S 61 E  
PERMIT/WAIVER NO. MO-3106 162-17-101-018  
issued by Water Resources Current Parcel No.

Subdivision Name: \_\_\_\_\_ County: Clark  
Latitude 36°07'37.15"N UTM E  NAD 27  
Longitude -115°11'18.20"W UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Silly Sand, fine grain			1	2
Silly Clay, stiff damp			2	7
Silly Sand w/gravel			7	9
Caliche			9	13
Silly Sand, fine dense			13	14
Sand w/gravel some silt			14	15
Sandy gravel, wet very dense			15	19
Clayey gravel, fine course, wet			19	20
Gravelly Sand, medium very course, wet			20	26
DOWNDRAWN RECEIVER				
OCT 28 2015				

9. INSTRUCTION  
Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)			
From		To	
8.25	Inches	0	Feet 25
	Inches		Feet
	Inches		Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	25

ANNULAR MATERIALS  
Sanitary Seal  Yes  No

<input type="checkbox"/> Neat Cement	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	0	to 11	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Bentonite Chips	11	to 13	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Gravel Pack [ > 0.2 in. ]	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Sand Pack [ < 0.2 in. ]	13	to 25	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input checked="" type="checkbox"/> Other, explain: <u>Sand 25-26</u>	25	to 26	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured

PERFORATIONS:  
Type of perforation: Factory  
Size of perforation: .020  
From 15 Feet To 25 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Date started: 10-15 20 15  
Date completed: 10-15 20 15

7. WATER QUALITIES  
Static water level: 17 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name National EWP Contractor  
Address 4221 W. Oquendo Rd. Las Vegas, NV 89118 Contractor

8. WELL TEST DATA			
Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		<u>0</u>	

Nevada contractor's license number as issued by the State Contractor's Board: 0075355  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526  
Signed: [Signature]  
Date: 10/28/2015

36.1270153  
- 115.1875555  
NAD  
27