STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 124006
Permit No.
Basin No. 087

NOTICE OF INTENT NO. 37906
WELL NAME (If applicable): MW-1

1. OWNER/CLIENT NAME Lauren Evans
MAILING ADDRESS 503 Modoc Street, Reno, NV

DETAILED ADDRESS AT WELL LOCATION 503 Modoc street
Reno, NV
Subdivision Name: Hamlin County: Washoe

2. PLS LOCATION SW ¼ SE ¼ 14 Sec 19 N/S 19 E
PERMIT/WAIVER NO. MO 2032 (Issued by Water Resources) 014-194-19 (Current Parcel No.)

Latitude ____ UTM E ____ ☑ NAD 27
Longitude ____ UTM N ____ ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☑ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Well graded sand.Backfill			0	12
Well graded sand w/silt and gravel			12	15
Silty sand ,moist,fine sand -coarse			15	26
Sand,wet,med. Dense,silty sand medium grained layers of well graded sand.		29	26	35
Sandy silt, moist,med. Dense, fine to medium sand, layers of clayey silt.			35	49
Well graded gravel with sand, dense,boulders, silt,wet.			49	60

DCNR/DWR/SNDO RECEIVED NOV 10 2015

NAD 27
39.508114°N
119.812442°W

Date started: 19-Oct, 20 15
Date completed: 19-Oct, 20 15

7. WATER QUALITIES
Static water level: 29 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 60 Feet Depth Cased: 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.01	0.237	0	60

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	0	to	36	☑ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	36	to	38	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	38	to	60	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..020

From	Feet	To	Feet
40	Feet	60	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 4221 W. Oquendo Rd. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0076355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526
Signed: (By driller performing actual drilling on site or contractor)
Date: 11/10/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg.