STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124079
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39490
WELL NAME *(If applicable)*: MW-12

1. OWNER/CLIENT NAME One Moon F & Wanda M Family TR
MAILING ADDRESS 8225 Horseshoe Bend LN
Las Vegas, NV 89113-0128

DETAILED ADDRESS AT WELL LOCATION 710 Casino Center Blvd.
Las Vegas, NV 89101
Subdivision Name: *County:* Clark

2. PLS LOCATION NW ¼ SW ¼ 34 Sec 20S N/S 61 E
PERMIT/WAIVER NO. MO-3098 *Issued by Water Resources* 139-34-310-032 *Current Parcel No.*

Latitude 36.163467 UTM E ☐ NAD 27
Longitude -115.149336 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
FILL			0	2
CLAY			0	10
CALICHE			10	13
CLAY			13	25

CONF/DWR/SNSP
RECEIVED
OCT 16 2015

Date started 9-Oct , 20 15
Date completed 9-Oct , 20 15

7. *WATER QUALITIES*
Static water level: 13 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 77 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	SCH 40	0	25

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	3	to	1	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	25	to	3	☐ Pumped	☒ Poured
☒ Other, explain: CONCRETE	1	to	0	☐ Pumped	☒ Poured

PERFORATIONS:
Type of perforation: MACHINE SLOTTED
Size of perforation: 0.02

From	Feet	To	Feet
25	Feet	5	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name EAGLE DRILLING SERVICES *Contractor*
Address 7150 PLACID ST. LAS VEGAS, NV 89119 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 51266
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2490-LTD
Signed: *By driller performing actual drilling on site or contractor*
Date 10/12/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** **pg. of pg.**

36.1634964
-115.148502
NAD 27