PZ-15

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124091
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38470
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME CC Public Righ of way
MAILING ADDRESS 500 Grand Central Pkwy
Las vegas, NV 89155

DETAILED ADDRESS AT WELL LOCATION None
Subdivision Name: *County:* Clark

2. PLS LOCATION SW¼ NW ¼ 29 Sec 21 N062 E
PERMIT/WAIVER NO. MO-3094 *Issued by Water Resources* 161-29-2994028 *Current Parcel No.*

Latitude 36.092998N UTM E ☐ NAD 27
Longitude 115.079527W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL# ____
☐ Replacement: Original well log # ____
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel			0	2	2
Sand w/clay			2	13	11
Gravel		13	13	16	3
Sandy clay			16	40	24

NDWR/DWR/SNRO RECEIVED OCT 08 2015

Date started: 9-16, 20 15
Date completed: 9-16, 20 15

9. WELL CONSTRUCTION
Depth Drilled: Feet Depth Cased: Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	sch 40	0	40

PERFORATIONS:
Type of perforation: Factory slot
Size of perforation: .020
From 10 Feet To 40 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

		to		
☐ Sanitary Seal				
☐ Neat Cement			☐ Pumped	☐ Poured
☐ Cement Grout			☐ Pumped	☐ Poured
☐ Concrete Grout	1	5	☐ Pumped	☒ Poured
☐ Bentonite Chips	5	8	☐ Pumped	☒ Poured
☐ Bentonite Grout			☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]			☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	8	40	☐ Pumped	☒ Poured
☐ Other, explain:			☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 13 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Elite Drilling Inc. *Contractor*
Address 4255 W. Post rd. LV, NV 89118 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 0054931
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* M-1869
Signed: *By driller performing actual drilling on site or contractor*
Date: 10-5-15

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY

36.0930244
-115.078697
NAD (O) 27