

PZ-14

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124092
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38469
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Clark County Public R/W
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas, NV 89155

DETAILED ADDRESS AT WELL LOCATION None
Subdivision Name: County: Clark

2. PLS LOCATION SW 1/4 NW 1/4 29 Sec 21 N 62 E
PERMIT/WAIVER NO. MO-3094 161-299-027
Issued by Water Resources Current Parcel No.

Latitude N 36.093017° UTM E
Longitude W 115.081250 UTM N
 NAD 27
 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL#
 Replacement: Original well log #
 Recondition: Original well log #

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Gravel			0	2'	2
Sandy/clay			2'	13'	11
Gravel		13'	13	15	2
Sandy clay			15	40	25

9. WELL CONSTRUCTION
Depth Drilled: 40 Feet
Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

From	To
8 Inches	0 Feet 40 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40 PVC	Sch 40	0	40

PERFORATIONS:
Type of perforation: Factory slot
Size of perforation: .020
From 10 Feet To 40 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
 Sanitary Seal to Pumped Poured
 Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout 1 to 5 Pumped Poured
 Bentonite Chips 5 to 8 Pumped Poured
 Bentonite Grout to Pumped Poured
 15 % 20 % Other, explain:
 Gravel Pack [> 0.2 in.] to Pumped Poured
 Sand Pack [< 0.2 in.] 8 to 40 Pumped Poured
 Other, explain: to Pumped Poured

Date started: 9/16 20 15
Date completed: 9/16 20 15

7. WATER QUALITIES
Static water level: 13 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Elite Drilling Inc.
Address: 4255 W. Post Rd LV, NV 89118
Nevada contractor's license number as issued by the State Contractor's Board: 0054931
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): M-1869
Signed: [Signature]
Date: 10/5/15

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			