STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124155
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73527
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Eric Johnson
MAILING ADDRESS 6045 Powerline Rd
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 6045 Powerline Rd
Fallon, NV 89406
Subdivision Name: County: Churchill

2. PLS LOCATION NE ¼ NE ¼ 6 Sec 18 N/S 28 E
PERMIT/WAIVER NO. (Issued by Water Resources) 006-251-21 (Current Parcel No.)

Latitude 39.4595 UTM E ☐ NAD 27
Longitude -118.8762 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	15
Brown Clay			15	18
Brown Sand			18	38
Brown Clay			38	52
Grey Sand			52	68
Grey Clay/Gravel			68	71
Grey Sand			71	89
Brown Clay			89	93
Grey Clay/Gravel			93	133
Grey Sand			133	150
Brown Clay			150	154
Brown Sand		X	154	160

NAD 27
39.459583
118.875212

Date started: 19-Nov, 20 15
Date completed: 19-Nov, 20 15

7. WATER QUALITIES
Static water level: 30 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30		1 hour

9. INSTRUCTION
Depth Drilled: 160 Feet Depth Cased: 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4	.312	18	160

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to	105	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to	160	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8"
From 156 Feet To 159 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 Fallon, NV 89407 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2509
Signed: [signature] By driller performing actual drilling on site or contractor
Date: 11/25/2015

RECEIVED 2015 DEC 14 PM 1:59 STATE ENGINEERS OFFICE

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown Well log