STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
MW80

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

OFFICE USE ONLY
Log No. 124172
Permit No.
Basin 090

NOTICE OF INTENT NO. 71246

1. OWNER VILLAGE SPRINGS LLC
MAILING ADDRESS 774 MAYS BLVD
INCLINE VILLAGE NV

ADDRESS AT WELL LOCATION 560 LAKESHORE BLVD
INCLINE VILLAGE, NV
Subdivision Name: County: WASHOE

2. LOCATION NE ¼ SE ¼ Sec 17 T 16 ☐N/S R 18 ☐E
PERMIT/WAIVER No. ~~84987-E~~ 122-128-07
Issued by Water Resources M/O 1987 Parcel No.

Latitude 39.349664 UTM E ☐ NAD 27
Longitude 119.980569 N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SEE ATTACHED				
LITH LOG				
NAD 27				
39.249757°N				
119.979546° W				

Date started: 6-8 20 15
Date completed: 6-10 20 15

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6"	Inches	0 Feet	80 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40 PVC	0	80

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .020
From 80 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 56 to 0 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 80 to 58 ☐ Pumped ☒ Poured
Type: #3
Bentonite Chips: ☐ Yes ☐ No 58 to 56 ☐ Pumped ☒ Poured
Type: 3/8 CHIPS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CASCADE DRILLING
Contractor
Address 3000 DULUTH ST
Contractor
WEST SACRAMENTO, CA
Nevada contractor's license number issued by the State Contractor's Board 73966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 24388
Signed
By driller performing actual drilling on-site or contractor
Date 6-10-15

RECEIVED JUN 15 2015 DIVISION OF WATER RESOURCES

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY