STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124227
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73393

1. OWNER Dave Thacker
MAILING ADDRESS 7482 Rockwood Place
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION 7482 Rockwood Place
Fallon, Nevada 89406
Subdivision Name: County: Churchill

2. LOCATION SW¼ SE ¼ Sec 13 T 19 N/S R 27 E
PERMIT/WAIVER No. Issued by Water Resources
Latitude Longitude
UTM E 0336482 N 4374458 ☒ NAD 27 ☐ NAD 83/WGS 84
Parcel No. 007-251-02

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sand		1	20	19
Brown clay		20	21	1
Brown sand	x	21	46	25
Brown clay		46	50	5
Grey sand		50	70	20
Grey clay		70	73	3
Grey sand		73	93	20
Grey clay	x	93	110	17

NAD 27
39.506088
118-901885

Date started: 05/14, 2015
Date completed: 05/14, 2015

9. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-3/4 Inches	0 Feet	100 Feet
6-5/8 Inches	100 Feet	110 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+1	110

Perforations:
Type of perforation Machine slot
Size of perforation .060
From 103 feet to 108 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corporation (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, Nevada 89407
Nevada contractor's license number issued by the State Contractor's Board 0011752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 5-19-15

RECEIVED 2015 MAY 21 AM 11:05 DIVISION OF WATER RESOURCES

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) Replacing unknown well log (O) 627