STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103626
Permit No.
Basin 266

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59806

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION Twin Creeks Mine
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SW ¼ Sec 8 T 39N N/S R 43 E
PERMIT/WAIVER No. M/O-1451
Issued by Water Resources Parcel No.

Latitude 41.274486
Longitude 117.153249
UTM E 486746.96595 [X] NAD 27
N 4569028.092188 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	210	210
Bedrock		210	960	750

Date started: 24-May, 20 07
Date completed: 12-Jun, 20 07

9. WELL CONSTRUCTION
Depth Drilled 960 Feet Depth Cased 960 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 5/8	Inches	0	Feet	20	Feet
6 3/4	Inches	20	Feet	~~460~~ 960	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8		.250	0	960

Perforations:
Type of perforation Slot
Size of perforation 1/8"
From 540 feet to 940 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [ ] No
[X] Neat Cement 55 to 0 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 960 to 539 [X] Pumped [ ] Poured
Type: 1/4" Gravel
Bentonite Chips: [X] Yes [ ] No 539 to 55 [ ] Pumped [X] Poured
Type: 3/8" Hole Plug

7. *Water Level*
Static water level: 445 feet below land surface
Artesian Flow: No G.P.M. P.S.I.
Water Temperature: 72 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
960	130	N/A	2 Hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1777
Signed Dennis L. White by (MK) (By driller performing actual drilling on site or contractor)
Date 12-Jun-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

Plugged by well log 103626