STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124259
Permit No. 83333 Order 1233
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73598
WELL NAME (*If applicable*): DW-75

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS PO Box 480, Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Gold Minesite, Round Mountain, NV.
Subdivision Name: *County:* Nye

2. PLS LOCATION SE ¼ SW ¼ 19 Sec 10 (N)S 44 E
PERMIT/WAIVER NO. 83333 (*Issued by Water Resources*) Order 1233 (*Current Parcel No.*)

Latitude UTM E 492837 [X] NAD 27
Longitude UTM N 4283857 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Monitor
[X] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [ ] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[X] Other Flooded Rev.

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Light grey rock			0	100
Grey rock w/clay			100	120
Grey rock			120	360
Dark grey rock			360	500
Light grey rock			500	840
Grey rock w/clay			840	890
Dark grey rock			890	900

NAD 27
38.705181
117.082379

Date started: 15-Nov, 20 15
Date completed: 11-Dec, 20 15

7. WATER QUALITIES
Static water level: 138 Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: 120 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
120	362	1

9. CONSTRUCTION
Depth Drilled: 900 Feet Depth Cased: 900 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	40	Feet
20	Inches	40	Feet	900	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.608	.375	0	40
12.75	33.375	.250	+2	900

ANNULAR MATERIALS

Sanitary Seal X Yes [ ] No

[X] Neat Cement	0	to	50	[ ] Pumped	X Poured
[X] Cement Grout	50	to	234	[X] Pumped	[ ] Poured
[ ] Concrete Grout		to		[ ] Pumped	[ ] Poured
[X] Bentonite Chips	234	to	274	[ ] Pumped	X Poured
[X] Gravel Pack [> 0.2 in.]	274	to	900	[ ] Pumped	X Poured
[ ] Sand Pack [< 0.2 in.]		to		[ ] Pumped	[ ] Poured
[ ] Other, explain:		to		[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: Louver
Size of perforation: 0.125

From	Feet	To	Feet
280	Feet	880	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 2475 California Ave, SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 0021976
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2486
Signed: (*By driller performing actual drilling on site or contractor*)
Date: 12/14/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1