STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124272
Permit No.
Basin No. 071

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71362
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Kenneth Peters
MAILING ADDRESS 4030 Artemesia Way
Winnemucca, NV 89445

DETAILED ADDRESS AT WELL LOCATION 10720 Reins Way
Winnemucca, NV 89445
Subdivision Name: Rawhide Estates *County:* Humboldt

2. PLS LOCATION NE ¼ SE ¼ 31 Sec 35 N/S 38 E
PERMIT/WAIVER NO. 3538-31 *Issued by Water Resources* — 476-003 *Current Parcel No.*

Latitude 40* 51.676 N UTM E ☐ NAD 27
Longitude 117* 44.375 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Clay and Gravel			0'	80'	80'
Clay and Gravel with			80'	275'	195'
Cobbles					
Gravel and Clay			275'	360'	85'
consolidated					
NAD 27					
40.861362					
117.738621					

Date started: 4-Jan , 20 16
Date completed: 7-Jan , 20 16

7. WATER QUALITIES
Static water level: 150' Feet below land surface
Artesian Flow: No G.P.M. 0 P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Airlift	40		3 Hours

9. WELL CONSTRUCTION
Depth Drilled: 360' Feet Depth Cased: 360' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11"	Inches	0'	Feet	360'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188"	+2'	360'

PERFORATIONS:
Type of perforation: Mill Slot
Size of perforation: 0.090"
From 300' Feet To 360' Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal		to		
☐ Neat Cement	0'	to 150'	☒ Pumped	☐ Poured
☒ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	150'	to 360'	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Stonehouse Drilling and Construction, LLC. *Contractor*
Address 7801 Lakeside Drive Reno, NV 89511 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 0069994
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* #1713

Signed: [signature] *By driller performing actual drilling on site or contractor*
Date: 01.13.16

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY