

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 124274  
Permit No. \_\_\_\_\_  
Basin No. 044

**PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 73725  
WELL NAME (if applicable): CM-NMW1

1. OWNER/CLIENT NAME Jerritt Canyon Gold LLC  
MAILING ADDRESS HC 31 Box 78 Elko NV 89801

DETAILED ADDRESS AT WELL LOCATION \_\_\_\_\_  
Jerritt Canyon  
Subdivision Name: \_\_\_\_\_ County: Elko

2. PLS LOCATION NW ¼ SE ¼ 5 Sec 40N/S 54 E  
PERMIT/WAIVER NO. M/O-2016  
*Issued by Water Resources Current Parcel No.*

Latitude 41 22' 57" UTM E \_\_\_\_\_  NAD 27  
Longitude 115 55' 06" UTM N \_\_\_\_\_  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGICAL LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Colluvium			0	20
Silt stone orange brown		X	20	105
Silt stone gray black			105	295
Quartzite gray black			295	400
Silt stone gray black			400	795
Cement 795'-417'				
3/8 Pel-Plug 417'-400'				
Can't get well casing				
Passed 350'				
3/8 Pel-Plug 400'-350'				
<u>NAD 27</u>				
<u>41.382591</u>				
<u>115.917418</u>				

9. INSTRUCTION  
Depth Drilled: 795 Feet Depth Cased: 350 Feet

HOLE DIAMETER (BIT SIZE)			
	From	To	
14-3/4	Inches 0	Feet 20	Feet
8-3/4	Inches 20	Feet 605	Feet
8-1/2	Inches 605	Feet 795	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		0.250	20	+2
4-1/2		Sch80 PVC	350	+18"

ANNULAR MATERIALS

Sanitary Seal	Yes	No		
Neat Cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>	10	to 0
Cement Grout	<input checked="" type="checkbox"/>	<input type="checkbox"/>	795	to 417
Concrete Grout	<input type="checkbox"/>	<input type="checkbox"/>		to
Bentonite Chips	<input checked="" type="checkbox"/>	<input type="checkbox"/>	298	to 10
Gravel Pack [ > 0.2 in. ]	<input checked="" type="checkbox"/>	<input type="checkbox"/>	350	to 298
Sand Pack [ < 0.2 in. ]	<input type="checkbox"/>	<input type="checkbox"/>		to
Other, explain:	<input type="checkbox"/>	<input type="checkbox"/>		to

PERFORATIONS:

Type of perforation: Mill Slot  
Size of perforation: 0.020

From	To	From	To
350	Feet	300	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

Date started: December 15, 20 15  
Date completed: December 20, 20 15

7. WATER QUALITIES  
Static water level: 100 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Boart Longyear Company  
Address PO Box 2748 Elko, NV. 89803

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input checked="" type="checkbox"/> Baller <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>2</u>		<u>3</u>
2-3/8 pipe			

Nevada contractor's license number as issued by the State Contractor's Board: 0021976  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2446  
Signed: [Signature]  
Date: 01/06/16