

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 124278  
Permit No. \_\_\_\_\_  
Basin No. 105

**PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 73309  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME ED FERANTO  
MAILING ADDRESS 1261 MEYERS DR  
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 1261 MEYERS DR  
GARDNERVILLE, NV 89410  
Subdivision Name: \_\_\_\_\_ County: Douglas

2. PLS LOCATION NW 1/4 SE 1/4 5 Sec 12 N/S 21 E  
PERMIT/WAIVER NO. 1221-05-002-012  
Issued by Water Resources Current Parcel No.

Latitude 38.930854°N UTM E  NAD 27  
Longitude 119.647558°W UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# N/A  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			0	60
COURSE DG SANDS			60	168
BROWN CLAY			168	220
FRACTURED GRAVELS		XXX	220	260
<u>NAD 27</u>				
<u>38.930945</u>				
<u>119.646552</u>				

9. INSTRUCTION  
Depth Drilled: 200' Feet Depth Cased: 200' Feet

HOLE DIAMETER (BIT SIZE)			
	From	To	
<u>6 1/8</u> Inches	<u>60</u> Feet	<u>260</u> Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>4.26</u>	<u>.216</u>	<u>40</u>	<u>260</u>

ANNULAR MATERIALS  
Sanitary Seal  Yes  No

<input type="checkbox"/> Neat Cement <u>N/A</u> to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Bentonite Chips _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Gravel Pack [ > 0.2 in. ] <u>N/A</u> to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Sand Pack [ < 0.2 in. ] _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Other, explain: _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

PERFORATIONS:  
Type of perforation: FACTORY MILL SLOT  
Size of perforation: 0.032

From <u>220</u> Feet	To <u>260</u> Feet
From _____ Feet	To _____ Feet
From _____ Feet	To _____ Feet
From _____ Feet	To _____ Feet

Date started: 28-Dec 2015  
Date completed: 2-Jan 2016

7. WATER QUALITIES  
Static water level: 65 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 46\* ° Fahrenheit  
Water Quality: GOOD

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC  
Contractor  
Address 20 KIT KAT DRIVE CARSON CITY, NV 89701  
Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>60</u>	<u>3 HOURS</u>

Nevada contractor's license number as issued by the State Contractor's Board: 0055548  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905  
Signed: [Signature]  
By driller performing actual drilling on site or contractor  
Date: 1/10/2015

*Deepening unknown well 100*