

0332882  
PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34895

1. OWNER PUBLIC RIGHT OF WAY ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 123 WASHINGTON AVE. LAS VEGAS, NV 89101 \_\_\_\_\_  
2. LOCATION NE 1/4 NW 1/4 Sec 27 T 20 N R 61 E CLARK County  
PERMIT NO. MO-2791 Issued by Water Resources Parcel No. 137-27-A9-015 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other USA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silty Clay w/ GRAVEL</u>		<u>0.0</u>	<u>2.0</u>	<u>2.0</u>
<u>SANDY CLAY</u>		<u>2.0</u>	<u>7.0</u>	<u>5.0</u>
<u>CLAYAY GRAVEL w/ SAND</u>		<u>7.0</u>	<u>9.0</u>	<u>2.0</u>
<u>SANDY CLAY w/ SILT</u>		<u>9.0</u>	<u>22.0</u>	<u>13.0</u>
<u>FAT CLAY w/ SAND</u>		<u>22.0</u>	<u>30.0</u>	<u>8.0</u>

MAP DATUM  
WGS 84  
Mw-2 36° 11' 16.22" N 115° 08' 38.15" W

NDWP#  
MO-2791

8. WELL CONSTRUCTION  
Depth Drilled 30 Feet Depth Cased 30 Feet  
HOLE DIAMETER (BIT SIZE)  
From 8 1/2 Inches To 30 Feet  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2.0 34 40 PVC 30 0  
Perforations:  
Type perforation MAchine SIt  
Size perforation .320  
From 30 feet to 10 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 8'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 30 feet to 8 feet

Date started 12/14 2007  
Date completed 12/14 2007

7. WELL TEST DATA  
TEST METHOD:  Bailer  Pump  Air Lift  
Drawdown (Feet Below Static) \_\_\_\_\_ Time (Hours) \_\_\_\_\_  
G.P.M. \_\_\_\_\_  
MAR 14 2008  
LAS VEGAS OFFICE

9. WATER LEVEL  
Static water level 17 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_  
10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE DRILLING SERVICES LLC Contractor  
Address 7150 RAVID ST. LAS VEGAS NV 89119 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 12/27/07