

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124344
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38088
WELL NAME (if applicable): well#140

1. OWNER/CLIENT NAME Clark County - Public Right of Way
MAILING ADDRESS 500 South Grand Central PKWY 2nd floor Las Vegas NV 84155
DETAILED ADDRESS AT WELL LOCATION Intersection of Hacienda Ave and Lamb BLVD., Clark County, Las Vegas NV.
Subdivision Name: _____ County: Clark

2. PLS LOCATION NW 1/4 SW 1/4 29 Sec 21S N/S 62 E Latitude 36.092532"N UTM E NAD 27
PERMIT/WAIVER NO. DW-1411 161-29-399-001 Longitude 115.082052"W UTM N NAD 83/WGS 84
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____
4. PROPOSED USE
 Domestic Irrigation Monitor Stock Rec
 Mining / Dewater Com / Ind Mun / QM
 Test / Other

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
Other _____

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
silty clay-silty clay&rock			0	10
silty clay&rock			10	13
packed dry clay			13	17
silty clay			17	19
hard packed clay			19	23
silty clay			23	27
hard packed clay			27	34
silty clay			34	40

9. INSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 40
Inches Feet
24 Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	40

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
Bentonite Chips 10 to 12 Pumped Poured
 Gravel Pack [> 0.2 in.] 0 to 40 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 6-Oct , 20 15
Date completed: 6-Oct , 20 15

7. WATER QUALITIES
Static water level: 16 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

PERFORATIONS:
Type of perforation: machine slot
Size of perforation: 0.032
From 20 Feet To 40 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Viking Drillers, Inc Contractor
Address 5950 Granite Lake Drive, Granite Bay, CA 95746 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2361
Signed: Matthew J. Perez
Date: 12/28/15
By driller performing actual drilling on site for contractor

36.0925584
- 115.081222
DUAL
27