STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124365
Permit No.
Basin No. 064

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74215
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Jay Wintle
MAILING ADDRESS 810 Sheep Creek Rd
Battle Mountain NV

DETAILED ADDRESS AT WELL LOCATION 685 Yellow Brick Rd
Battle Mountain NV
Subdivision Name: *County:* Lander

2. PLS LOCATION SE ¼ SE ¼ 14 Sec 32 N/S 44 E
PERMIT/WAIVER NO. Lot 12 *Issued by Water Resources* 010-280-30 *Current Parcel No.*

Latitude N40*38'31.043 UTM E ☐ NAD 27
Longitude W116*58'54.000 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	5
Brown sandy clay		50	5	90
Blue clay sand gravel		Yes	110	180

NAD 27
40.642045
116.980731

Date started: ~~3 Jan~~ 1-10 , 20 16
Date completed: ~~01/10/16~~ 1-17 , 20 16

9. CONSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	180

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	20	☐ Pumped	☒ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to	50	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	180	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From 140	Feet	To 180	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: 35 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	N/A	8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc. *Contractor*
Address 5140 Jungo Rd Winnemucca NV *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1563

Signed *By driller performing actual drilling on site or contractor*
Date: 1-22-16

RECEIVED 2016 FEB -1 PM 1:35 STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.