STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124378
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73313
WELL NAME (if applicable):

1. OWNER/CLIENT NAME NORMA SANTOYO
MAILING ADDRESS 2584 MACKAY WAY
MNDEN, NV 89423

DETAILED ADDRESS AT WELL LOCATION 2584 MACKAY WAY
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. PLS LOCATION ~~NW~~ ¼ NE ~~NE~~ ¼ NW ¼ Sec 13 N/S 20 E
PERMIT/WAIVER NO. 1320-02-001-105
Issued by Water Resources Current Parcel No.

Latitude 39.023183*N UTM E ☐ NAD 27
Longitude 119.705546*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			0	280
GRAY DG SANDS			280	305
GRAY CLAY			305	330
GRAY DG SANDS		XXX	330	380

NAD 27
39.023274
119.704537

RECEIVED FEB 4 2016 STATE ENGINEER'S OFFICE

Date started: 26-Jan , 20 16
Date completed: 28-Jan , 20 16

7. WATER QUALITIES
Static water level: 225 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 47° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
18	65	3 HOURS

9. INSTRUCTION
Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	280	Feet	380	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	4.26	.216	260	380

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	Feet	To	Feet
340	Feet	380	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael Hack
By driller performing actual drilling on site of contractor
Date: 1/29/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepening unknown well 109