STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124380
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73311
WELL NAME (if applicable):

1. OWNER/CLIENT NAME ~~ROCKY WALLING CONSTRUCTION~~ John Fisher
MAILING ADDRESS 1316 WILSON CIRCLE
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 1579 CHIQUITA
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. PLS LOCATION SE ¼ SE ¼ 34 Sec 14 N/S 20 E
PERMIT/WAIVER NO. 1420-34-811-022
Issued by Water Resources Current Parcel No.

Latitude 39.028555*N UTM E ☐ NAD 27
Longitude 119.715845*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BLOW SANDS			3	8
DG SANDS			8	165
BROWN CLAY			165	180
BROWN STICKY CLAY			180	210
DG SANDS AND CLAY SEAMS			210	230
GRAY CLAY			230	235
FRACTURED DG SANDS AND GRAVELS		XXX	235	280

RECEIVED
2016 FEB 14 AM 10:53
NV STATE ENGINEER'S OFFICE

Date started: 5-Jan , 20 16
Date completed: 11-Jan , 20 16

7. WATER QUALITIES
Static water level: 125 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 47° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	40	3 HRS
	NAD 27	
	39.028646	
	119.714835	

9. WSTRUCTION
Depth Drilled: 280 Feet Depth Cased: 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	100	Feet
9 7/8	Inches	100	Feet	280	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	280
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☐ Pumped	☐ X Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	280	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 3 X 3/32

From 240	Feet	To 260	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CATITAL CITY WELL DRILLING AND PUMP SERVICE INC
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: [signature]
By driller performing actual drilling for the contractor
Date: 1/25/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.