

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 124417  
Permit No. \_\_\_\_\_  
Basin No. 083

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 74268  
WELL NAME (if applicable): well#4

1. OWNER/CLIENT NAME Reno City of  
MAILING ADDRESS PO BOX 1800 C/O Property  
Management Reno NV 89505

DETAILED ADDRESS AT WELL LOCATION 6800 Pembroke Dr.

2. PLS LOCATION SE ¼ NE ¼ 28 Sec 19M N/S 20 E  
PERMIT/WAIVER NO. DW-120 021-160-44  
Issued by Water Resources Current Parcel No.

Subdivision Name \_\_\_\_\_ County Washoe  
Latitude 39 29' 07.71 UTM E  NAD 27  
Longitude 119.44' 09.93 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WLS \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Opportunity  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Dark Piate silty - dark clay lens			0	5
silty sand			5	8
sand & gravel			8	18
hard clay			18	21
			21	25
Plugged By Well Log 126296				
NAD 27				
39.485563				
119.735071				

9. INSTRUCTION

Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>24</u> Inches	<u>0</u> Feet <u>25</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Fl. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>3/8</u>	<u>0</u>	<u>25</u>

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout 6 to 8  Pumped  Poured

Bentonite Chips 10 to 12  Pumped  Poured

Gravel Pack (> 0.2 in.) 0 to 25  Pumped  Poured

Sand Pack (< 0.2 in.) \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

PERFORATIONS:

Type of perforation: machine slot

Size of perforation: 0.032

From 20 Feet To 25 Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Date started: 30-Nov . 20 15

Date completed: 30-Nov . 20 15

7. WATER QUALITIES

Static water level: 8 Feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: \_\_\_\_\_ ° Fahrenheit

Water Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Viking Drillers, Inc Contractor

Address 5950 Granite Lake Drive, Granite Bay, CA 95746 Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number as issued by the State Contractor's Board: 0634680

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2381

Signed: Matthew J. [Signature]

Date: 2/12/16

RECEIVED  
FEB 16 PM 2:57  
THE ENGINEER OFFICE