STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124429
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73542
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Dan Allen
MAILING ADDRESS 1050 Gummow Dr
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 1050 Gummow Dr
Fallon, NV 89406
Subdivision Name *County:* Churchill

2. PLS LOCATION SW ¼ SW ¼ 23 Sec 19 N/S 28 E
PERMIT/WAIVER NO. DOM 15-54 *Issued by Water Resources* 008-253-13 *Current Parcel No.*

Latitude 39.49025 UTM E ☐ NAD 27
Longitude -118.8176 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	35
Black sand			35	38
Brown Clay			38	41
Brown Sand			41	50
Green Sand			50	73
Gray Clay			73	84
Brown Sand		X	84	105

RECEIVED NOV 18 AM 11:08 DIVISION OF WATER RESOURCES

NAD 27
39.490333
118.816613

Date started: 2-Nov , 20 15
Date completed: 3-Nov , 20 15

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 105 Feet Depth Cased: 105 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	105	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	20
6	4	.312	20	105

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	105	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other explain.		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.

From	Feet	To	Feet
102	Feet	105	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board.* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2509
Signed: *By driller performing actual drilling on site or contractor*
Date 11/11/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing unknown well log