

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
Log No. 124476
Permit No. _____
Basin No. 071

**PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74213
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Justin Massie
MAILING ADDRESS 9305 Sabin Dr
Winnemucca NV 89445

DETAILED ADDRESS AT WELL LOCATION 9305 Sabin Dr
Winnemucca NV 89445
Subdivision Name: 0.473 Tycana County: Humboldt

2. PLS LOCATION NE 1/4 NE 1/4 30 Sec 35 N/S 38 E
PERMIT/WAIVER NO. 3538-302-00-031
Issued by Water Resources Current Parcel No.

Latitude N40°53'21.457 UTM E NAD 27
Longitude W117°44'19.406 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand and gravel		No	0	6
Coarse gravel, cobbles sand clay		No	6	140
Cemented gravel sand cobbles clay			305	140 400
NAD 27 40.883561 117.737761				

9. INSTRUCTION

Depth Drilled: 400 Feet Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8" Inches	0 Feet 400 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	400

RECEIVED
2016 FEB 29 PM 12:45
STATE ENGINEERS OFFICE

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement 0 to 20 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 20 to 50 Pumped Poured
 Gravel Pack [> 0.2 in.] 50 to 400 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

PERFORATIONS:

Type of perforation: slot
Size of perforation: 0.2

From 340 Feet To 400 Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet

7. WATER QUALITIES
Static water level: 105 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc. Contractor
Address 5140 Jungo Rd Winnemucca NV Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>7</u>

Nevada contractor's license number as issued by the State Contractor's Board: 76778
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1563

Signed: At 7
By driller performing actual drilling on site or contractor
Date: 2-23-16