

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124482
Permit No. _____
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73786

1. OWNER/CLIENT NAME ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

DETAILED ADDRESS AT WELL LOCATION 1864 AMBER WAY

WELL NAME (If applicable): _____

2. PLS LOCATION NW ¼ SE ¼ 28 Sec 34N N/S 55 E
PERMIT/WAIVER NO. 006-09P-196
Issued by Water Resources Current Parcel No.

Subdivision Name: SPECIAL LANDS County: ELKO
Latitude UTM E 602670 NAD 27
Longitude UTM N 4517122 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic
 Mining / Dewater
 Test / Other

Irrigation Monitor
 Com / Ind Stock
 Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM			0	10'
LIGHT GREEN CLAYS			10'	120'
DRAK GREEN CLAYS			120'	580'
DRAK GREEN CLAYS & RED VOLCANICS			580'	640'

9. INSTRUCTION
Depth Drilled: 640' Feet Depth Cased: 640' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>640'</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>13</u>	<u>.188</u>	<u>+1.5</u>	<u>640'</u>

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement 0 to 25' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 25 to 50' Pumped Poured
 Gravel Pack [> 0.2 in.] 50' to 640' Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain. _____ to _____ Pumped Poured

PERFORATIONS:

Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4"

From	Feet	To	Feet
<u>600'</u>		<u>640'</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name HACKWORTH DRILLING INC. Contractor
Address P.O. BOX 850, ELKO, NV 89803 Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 020582
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2329

Signed: [Signature]
Date: 1/12/2016
By driller performing actual drilling on site or contractor

7. WATER QUALITIES
Static water level: 33' Feet below land surface
Artesian Flow: _____ G.P.M. P.S.I.
Water Temperature: 134 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>640'</u>			
<u>300'</u>	<u>110</u>		
<u>300-200</u>	<u>100</u>		<u>2HRS</u>
<u>200'-100'</u>	<u>90</u>		<u>1HR</u>
<u>80</u>	<u>25</u>		<u>1HR</u>
			<u>.5HR</u>

RECEIVED
2016 FEB 22 AM 11:30
STATE ENGINEERS OFFICE

NAD 27
40.800589
115.782921

Date started: 6-Jan 20 16
Date completed: 11-Jan 20 16

Replaced by LOG 125534
Plugged by LOG 126364

USE ADDITIONAL SHEETS IF NECESSARY