STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124485
Permit No. 80645
Basin No. 042

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72781
WELL NAME (if applicable)

1. OWNER/CLIENT NAME Naveran (James) Family Trust
MAILING ADDRESS P.O. Box 869
SE Wells, NV 89835

DETAILED ADDRESS AT WELL LOCATION North of Wells, NV
Subdivision Name County Elko

2. PLS LOCATION ~~SW~~ ¼ NE ¼ ~~7~~ 15 Sec 39 N/S ~~S~~ 62 E
PERMIT/WAIVER NO. ~~72781~~ 80645
Issued by Water Resources Current Parcel No.

Latitude N41°16'54.24 UTM E ☐ NAD 27
Longitude W115°00'23.04 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Top Soil			0	2
Brown Clay			2	6
Siltstone			6	14
Gravel/Siltstone			14	60
Boulders/gravel/Siltstone			60	90
Black Ryolite			90	130
Fractured Ryolite			130	260
		X	260	300
		X	300	340
		X	340	404

RECEIVED 2016 MAR -2 AM 10:39 STATE ENGINEERS OFFICE

NAD 27
41.281815
115.005523

Date started: 20-Dec , 20 15
Date completed: 9-Feb , 20 16

7. WATER QUALITIES
Static water level: 170 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 58 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
1100+		48

9. INSTRUCTION
Depth Drilled: 408 Feet Depth Cased: 404 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	408	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		250	+2	404

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 105	☒ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	105	to 404	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: mill slot
Size of perforation: 3/16x3

From 280	Feet	To 400	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Fertig Drilling Company (Contractor)
Address 422 Elko Summit #2, Elko, NV 89801 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board 031904
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller) 1689
Signed (Driller performing actual drilling on site or contractor)
Date 2-25-16

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.