STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124629
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37925
WELL NAME *(If applicable)*: A

1. OWNER/CLIENT NAME CV Propco LLC
MAILING ADDRESS 1505 South Pavillion Center DR.
Las Vegas, NV 89135

DETAILED ADDRESS AT WELL LOCATION 3485 W. Harmon Ave
Las Vegas, NV 89103
Subdivision Name: *County:* Clark

2. PLS LOCATION NW ¼ SW ¼ 20 Sec 21 N/S 61 E
PERMIT/WAIVER NO. MO-3113 *Issued by Water Resources* 162-20-301-005 *Current Parcel No.*

Latitude 36.1804*N UTM E ☑ NAD 27
Longitude 115.18655*W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Silty Sand w/ trace gravel			0	5
Clayey sand w/ gravel			5	9
Caliche			9	10
Sandy Silt			10	14
Sandy Clay		23	14	25
Caliche			25	27
Sandy Clay			25	29

DCNR/DWR/SNBC RECEIVED FEB 18 2016

Date started: 1-Feb , 20 16
Date completed: 1-Feb , 20 16

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 29 Feet Depth Cased: 29 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	29	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.01	0.237	0	28

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	0	to	8	☑ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	8	to	11	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	11	to	28	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..020

From	13	Feet	To	28	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP *Contractor*
Address 4221 W. Oquendo RD. Las Vgeas, NV 89118 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2526
Signed: *by driller performing actual drilling on site or contractor*
Date: 2/9/2016

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.