STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124669
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35671

1. OWNER Jenifer Bailey
MAILING ADDRESS PO Box 411 Alamo NEV 89001
ADDRESS AT WELL LOCATION 403 Alamo West Road
Alamo NEV. 89001
Subdivision Name —
County: Lincoln

2. LOCATION SW/4 NE ¼ Sec 31 T 6 N/S R 61 E
Latitude N37°23.103 UTM E ☐ NAD 27
PERMIT/WAIVER No. — 011-191-18 Issued by Water Resources
Longitude W115°10.830 N ☒ NAD 83/WGS 84
Parcel No.

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand - Boulders				
White Clay		0	70	70
Clay - Boulders		70	85	15
Fractured Rock		85	110	25
Clay sand - Gravel	X	110	150	40
Sand - Boulders	X	150	190	40
Brown Clay		190	200	10
7' of 6" steel casing was				
grouted over pvc casing				
at surface				

DCNR/DWR/SNDO RECEIVED DEC 10 2015

Date started: 11-30-2015, 20
Date completed: 12-4-2015, 20

7. Water Level
Static water level: 120 feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: cold °F
Quality: fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Sch 40	0	200

Perforations:
Type of perforation 1/8" x 3"
Size of perforation saw cut
From 100 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type: #8 minus
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NEV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191

Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 12-6-2015

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY

37.385114
-115.1796377
NAD 27

(NSPO 3-08)

(O) 627