STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124694
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38743
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Jose Rios
MAILING ADDRESS P.O. Box 711 Dallas, Tx. 75221

DETAILED ADDRESS AT WELL LOCATION 30 W. Wyoming Las Vegas, NV
Subdivision Name: County: Clark

2. PLS LOCATION SE ¼ NE ¼ 3 Sec 21 N/S 61 E
PERMIT/~~WAIVER NO.~~ MO-3132 16263216010
Issued by Water Resources Current Parcel No.

Latitude 36.152520 UTM E ☐ NAD 27
Longitude -115.135041 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown silty Clayey Sand			0	23'

DCNR/DWR/SNBC
RECEIVED
JAN 28 2016

Date started: 1-21 , 20 16
Date completed: 1-21 , 20 16

9. INSTRUCTION
Depth Drilled: 23' Feet Depth Cased: 22' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8'	Inches	0	Feet	23'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch-40	Sch-40	0	22'

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 16'	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	16'	to 18'	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]	18'	to 23	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: 020

From	Feet	To	Feet
19'		22	

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling
Contractor
Address 4590 Copper Sage St. Las Vegas
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* M1935
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 0073966

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 1-27-16

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1525493 NAD
-115.1542073 27