STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124700
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38906
WELL NAME *(If applicable)*: mw1

1. OWNER/CLIENT NAME School Board of Trusees
MAILING ADDRESS 4190Mcleod Dr 2nd flr
Las vegas Nv

DETAILED ADDRESS AT WELL LOCATION 1420E Pearl ave
Clark County sand valley Nv
Subdivision Name *County:* Clark

2. PLS LOCATION NE ¼ sw ¼ 32 Sec 24 N/S 57 E
PERMIT/WAIVER NO. mo-3114 *Issued by Water Resources* 201-32-301-001 *Current Parcel No.*

Latitude 35.813155 UTM E ☐ NAD 27
Longitude -115.611529 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
top soil			0	1
sandy graver			1	60
graveer with cobbles			60	80
clay sand			80	90
sand & gravel clay			90	110

Date started: 19-Nov , 20 15
Date completed: 20-Nov , 20 15

9. CONSTRUCTION
Depth Drilled: 8 Feet 110 Depth Cased: 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	pvc	sch-80	0	110

ANNULAR MATERIALS

Sanitary Seal x ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	5	☐ Pumped	☒ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
Bentonite Chips		to		☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	110	to	88	☐ Pumped	☒ Poured
☒ Other, explain: Aquld grout	88	to	5	☒ Pumped	☐ Poured

DCNR/DWR/SNBO
RECEIVED
DEC 09 2015

PERFORATIONS:

Type of perforation: machine slot
Size of perforation: 0.02

From	90	Feet	To	110	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

7. *WATER QUALITIES*
Static water level: 93 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 71 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Eagle Drilling Services *Contractor*
Address 7150 Placid Las Vegas NV 89119 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 51266
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* Timothy Thompson 2097
Signed. *By driller performing actual drilling on site or contractor*
Date. 12/7/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

35.8137799 NAD
-115.6106903 27